


Regional Water Testing Laboratory, Amritsar

Date : 08/07/2021

S No	Registration No	District	Block	Name of Place/Village	Sample Receipt Date	Date of Collection	Source	Depth	pH	TDS (mg/l)	Total Alkalinity (mg/l)	Total Hardness (mg/l)	Turbidity	Calcium (mg/l)	Magnesium (mg/l)	Chloride (mg/l)	Odour	Taste	Colour
As per IS 3025-2017 : Requirement (Acceptable limit - Permissible limit) mg/L									6.5 - 8.5	500 - 2000	200 - 600	200 - 600	1 - 5 NTU	75 - 200	30 - 100	250 - 1000			
I	RWTLASU/765	Amritsar	NA	Ajanta Public School, Basant Avenue, 142006	06-07-2021	NM	MCSW	NA	7.4	296	280	220	1.84	19.23	41.79	12.00	Agreeable	Agreeable	NA

End of Report


Quality Manager/Sr. Chemist
 Senior Chemist
 Authorised Signatory
 For Regional Water Testing Laboratory,
 Amritsar